Mob : 99457 44759

Shriya Construction and Consultancy

1133, 3rd Floor, 3rd Stage, B Cross, Yelahanka New Town, Bangalore - 560 064.

NO: YEL/PMC/ CHO/RAFT 01

Date: 11/01/2020

1. **Test report on cement Concrete Cubes:**

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Project: Name of work:"Asphalting to roads at chowdappa layout , Maruthi Layout, Hillside Medows and surrounding areas in ward no -03 Yelahanka Satellite Town sub Division"

Ref: Material Testing/PMC/19-20

Report submitted to: Assistant Executive Engineer, Yelahanka Sub Division, BBMP Bangalore.

Name of Agency/ contractor: M/s KRIDL Bangalore.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M20**

Table 1.1

SL No	Location	Date of casting	Date of Testing	C/S Area mm2	Age	Load KN	Compressive Strength-N/mm2	Average
1.	Raft concrete BHEL Layout	4/1/20	11/1/20	22500	7	390	17.33	18.14
2.	"	"	"	"	"	425	18.88	
3.	"	"	"	"	"	410	18.22	

SHRIYA C.C. CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ.
ಜ.ಜ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-೫೬೦